

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234205

Address: 1441 SW WINTHROP TER, LEES SUMMIT, MO 64081
1443 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Friday, May 24, 2024

Corrective Action Required:

1	Misc	-Missing loop at dishwasher under kitchen sink both units
		-Secondary locks at patio doors not operating correctly both units

Comments: