CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20236649 Address: 2233 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	n:	Inspector:	Outcome:	Date:
Electrical	Service Inspection	Alex Fischer	Passed	Monday, May 20, 2024
Corrective Action Required: 1 Misc		-Land conductors from ma -Bond gas line	in service panel to sub pane	el

Comments: