

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240912
Address: 420 SW LONGVIEW BLVD, Unit:100, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Failed	Friday, May 24, 2024

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Treatment 1. Provide outlet cover by sink- Provide anti hammer device at laundry- Provide cover at GFCI outlet at laundry- ADA compliant mirror needs to be provided- Install ADA compliant toilet paper dispenser |
|---|------|--|

Ok to bring in equipment, furniture. Leave washer away from wall

Comments: