



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113275, Building Permit - Commercial  
Address: 691 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Failed	Monday, September 12, 2011

Corrective Action Required  
2 MISC

TEMPORARY LIGHTING FIXTURES AND WIRING TO BE REMOVED FROM ABOVE CEILING

Corrective Action Required  
3 MISC

SOME CEILING SUPPORT WIRES NOT RUN STRAIGHT FROM BAR JOISTS TO GRID -- EXAMPLE: WAITING AREA; CHECK ALL

Corrective Action Required  
4 MISC

LIGHT FIXTURES NOT INSTALLED AT SPACES: TILITTY; BREAK; MEN'S

Corrective Action Required  
5 MISC

JUNCTION BOXES OPEN FOR EXTERIOR SIGN INSTALLATION

**Comments:**