

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240888  
Address: 1833 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, May 28, 2024

Corrective Action Required:

1	Miscellaneous Correction	<b>**Remove blockings. Do not block the return air space above top landing of stair to basement</b>
		<b>-Master bathroom toilet vent fan is not hooked up to flex vent pipe **Tape connection of flex duct to bath fan</b>
		<b>**OK TO INSULATE</b>

**Comments:**