

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236294

Address: 2118 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082
2116 SW HOLDBROOKS DR, LEES SUMMIT,
MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, May 28, 2024

Corrective Action Required:

1	Miscellaneous Correction	2118-OK
---	--------------------------	---------

2116:

-Seal underneath both chases in the garage ** provide 5/8" gypsum underneath garage boxed-out walls

Both units:

plot has not had it's final grading for plot plan inspection

Sod, splash pads and sump pump extensions are not complete

Comments: