

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240962
Address: 1925 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, May 28, 2024

Informational:

1 Misc

Corrective Action Required:

2 Miscellaneous
Correction

- Fire block garage to house chase at the top

- Bedroom 2 fire blockk wall space to celing space
-fire block furr down ends in basement

Mechanical HVAC piping needs to have BOCA plates at the top plate and sole plate

Comments: