



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRSUBD20201709, Public Infrastructure
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
PW Bond Inspection	Matt Munger	Partial	Tuesday, May 28, 2024

Corrective Action Required

1 Misc

Bond Inspection - There are two manholes on SW Farm Field Court that will need to be adjusted as they stick up and there appears to be a little bit of settlement around them. MH 50-307 and MH 50-308.

Comments: