

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240997
Address: 4402 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Kyle Beard	Failed	Wednesday, May 29, 2024

Corrective Action Required:

1	Miscellaneous Correction	- Door latching mechanism is missing from the rec room into the mechanical room - Smoke/carbon monoxide are not working
---	--------------------------	--

Comments: