

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240902  
Address: 1928 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Failed	Wednesday, May 29, 2024

Corrective Action Required:

4	Miscellaneous Correction	-Fasten interior CS-WSP according to engineers letter -Install triple windows in great room and bedroom 1 according to plan -Replace broken header at triple window in great room
---	--------------------------	---

**Comments:**