

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240902
Address: 1928 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, May 28, 2024

Informational:

1	Miscellaneous Correction	Garage portal inspection only. Passed and ok to cover
---	--------------------------	---

This is a partial pass only

Corrective Action Required:

2	Misc	-CS-WSP interior to be installed at reinspect -have engineer address detail for rear great room windows not in plans -complete fireblocking 1st floor -steel columns placed -all anchor bolts to be tight -sister notched wall studs in basement
---	------	---

Corrective Action Required:

3	Misc	NO PLANS ON SITE
---	------	------------------

Comments: