

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240902  
Address: 1928 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, May 24, 2024

Informational:

1	Miscellaneous Correction	Garage portal inspection only. Passed and ok to cover
---	--------------------------	---

This is a partial pass only

Corrective Action Required:

2	Misc	<ul style="list-style-type: none"><li>-CS-WSP interior to be installed at reinspect</li><li>-have engineer address detail for rear great room windows not in plans</li><li>-complete fireblocking 1st floor</li><li>-steel columns placed</li><li>-all anchor bolts to be tight</li><li>-sister notched wall studs in basement</li></ul>
---	------	--

Comments: