



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113001, Building Permit - Commercial
Address: 1499 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Failed	Monday, September 12, 2011

Corrective Action Required
1 MISC

1. REVISE PLANS TO SHOW CHANGE IN RATED WALL/CEILING IN CORRIDOR.
2. PENETRATIONS IN WALL SHALL BE SEALED BY APPROVED METHOD.
3. 2 LAYERS INSTALLED ON CEILING IN MAIN CORRIDOR, HALL TO THE NORTH ONLY 1 LAYER INSTALLED ON CEILING.
4. 10 CANLIGHTS INSTALLED IN MAIN CORRIDOR CEILING, PROVIDE APPROVED METHOD OF OPENING/PENETRATION.

Comments: