

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226269
Address: 2206 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|------------------------|
| Occupancy Inspection - Codes Residential | Alex Fischer | Failed | Thursday, May 30, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -No drain hose loop under sink at dishwasher -Loose joist hangers at deck -Missing 1/2 inch through bolts at post to beam connections at deck -Secure AC whip within 1 ft of disconnect -Missing light fixtures at rear of house -Missing sod and splash blocks -Upload 3rd party inspection for piers and footings |
|---|------|---|

Comments: