



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113089, Building Permit - Commercial  
Address: 930 NW BLUE PKWY, Unit:V, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Tuesday, September 13, 2011

Partial Correction

1 MISC

OK TO COVER WHEN READY SOFFITS TO RECEIVE GWB

Partial Correction

2 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING AND ABOVE-CEILING SYSTEMS EXCEPT AT THREE 2x2 LIGHT FIXTURES YET TO BE INSTALLED

**Comments:**