

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20236555
Address: 1020 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Devon Perry	Passed	Friday, May 31, 2024

Informational:
1 Misc 5-30-24 DP. Contractor completed vacuum testing today.
A-3- passed- 2 min
A-2- passed- 2 min
A-1- passed- 2 min

Comments: