

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20215636  
Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Devon Perry	Passed	Friday, May 31, 2024

Informational:

1 Misc

5-2-23 DP. Crew performed vacuum tests on new Manholes 4-1,2-1 and 1-1 and they all passed.

5-24-23 DP. Crew performed vacuum tests on New Manholes 1-2,1-3,1-4,4-2 and existing Manholes after being restacked #35-410 and 35-411. All passed

**Comments:**