

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192646
Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Plumbing Inspection - Commercial	Robb Popp	Failed	Friday, May 31, 2024

Corrective Action Required:

1	Misc	5/31/24
Inspection for grease interceptor:		
-No grease interceptor detail or specifications on building or civil plans.		
Submit updated plan revisions for approval		

Comments: