## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20231105

Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Robb Popp Partial Friday, May 31, 2024

Commercial

Informational:

1 Misc

Corrective Action Required:

2 FIRST FLOOR Building A:

-Decks approved

-Sheer wall framing ok for plywood

\*UNITS APPROVED EXCEPT AS NOTED BELOW

112

-Provide engineerd correction for cut trusses near entry

-Provide 1.5" of bearing for beam outside of unit 289

\*\*Building C:

-Pre rock behind tubs and showers approved

Corrective Action Required:

3 SECOND FLOOR Building A:

Decks approved
Shear walls approved

Building B:

-Shear walls behind tubs ok

		-Deck framing ok
Campativa As	e Action Required: THIRD FLOOR	**Building C: -Pre rock behind tubs and showers approved
		*BUILDING A: -Approved
		*Building B: 315 -Complete fireproofing at structural steel column
		-318 -Protect dryer box at corriidor -Missing H2.5s at deck
		***Pre rock at tubs and showers approved
Corrective Action Required:		**Building C: -2 HOUR WALLS OK FOR ROCK
	FOURTH FLOOR	*BUILDING A: -Approved
		*Building B: -Approved
		*Building C: -OK for pre rock behind tubs and showers
Corrective Action Required:		
6 EL	EVATOR 1	**ELEVATOR A: -Ok for rock on inside of shaft all floors
Corrective Action Required:		
	AIR TOWER 5	Stair tower D: -Shear wall nailing pattern complete
Corrective Action Required:		Silved Wall Halling pattern complete
	AIR TOWER 1	*Stair A
		-Approved walls and ceiling all floors
Corrective Action Required:		
9 EL	EVATOR 2	Elevator in building C -Framing approved
Corrective Ac	9 approve	
	AIR TOWER 2	Stair 2 in Building B

-Approved walls and ceiling all floors

-Approved walls and ceilng all floors

Stair 2B in Building B

Corrective Action Required:

11

STAIR TOWER 3

<b>Comments:</b>	
------------------	--