

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240759
Address: 3517 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Monday, June 03, 2024

Corrective Action Required:

1	Misc	-House numbers are not properly illuminated -Missing loop at dishwasher drain hose under kitchen sink -Address self closing hinges at garage door need adjusted -Missing sod, splash blocks and sump pump extension pipe
---	------	---

Comments: