

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240644
Address: 1617 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, June 03, 2024

Corrective Action Required:

1	Misc	-tighten all anchor bolts in garage -seal all hvac chase into furr down in garage -missing nails in lib flex room, bed 3 -(3) 2x4 at flex room window per plans -nail all exterior wall corners to code
---	------	---

Comments: