

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240499
Address: 2237 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Monday, June 03, 2024

Corrective Action Required:

1	Misc	-Ground service to building steel per NEC 250.66 with 2/0 copper or 4/0 aluminum grounding electrode conductor -Verify grounding to ufer and water service -Cannot have more than 2 conductors in same lug -Insulation bushings installation not compliant -Make sure to tighten the service raceway on lock nuts really good
---	------	---

Comments: