

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242214
Address: 3816 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Kyle Beard	Partial	Monday, June 03, 2024

Informational:

1	Miscellaneous Correction	PEX is ran out from the foundation about 20 feet. Okay to cover This is a partial pass only
---	-----------------------------	----------------------------------------------------------------------------------------------------

Comments: