

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240133
Address: 2763 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, June 04, 2024

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Address over notched stud on south wall garage- Missing triple hanger joists headered between garage bays- Complete cs-pf nailing on sheeting in breakfast- Minimum of 3 studs on exterior corners basement both sides at back of house- Address post to beam connections at deck- Missing nails in joist hangers at deck |
|---|------|--|

Comments: