



# Proofroll Inspection

Alpha Omega Geotech, Inc  
1701 State Avenue  
Kansas City, KS 66102  
Phone: 913-371-0000

**Client:**  
Tailor Made Exteriors  
1610 SE Hamblen Rd  
Lee's Summit, MO 64081

**Project:**  
230445  
TM Fieldhouse  
1600 SE Hamblen Rd  
Lees Summit, MO 64081

**Date:** 02/29/2024

**Inspector:** Zaii Graves

**Temperature (F):** 54

**Weather:** Sunny

## OBSERVATIONS

**Location:** TM Fieldhouse. West building pad. East side.

**Equipment Used:**

Water truck half full. Approximately 70-80K lbs.

**Description Of Subgrade:** Brown dirt

**Acceptance of Subgrade:** Yes

**Remarks:** Approximately 30-50 ft going east from middle of site was not checked for proof roll. Excavation pile was there.

Reviewed by: Cody Curtis

03/06/2024