



Proofroll Inspection

Alpha Omega Geotech, Inc
1701 State Avenue
Kansas City, KS 66102
Phone: 913-371-0000

Client:
Tailor Made Exteriors
1610 SE Hamblen Rd
Lee's Summit, MO 64081

Project:
230445
TM Fieldhouse
1600 SE Hamblen Rd
Lees Summit, MO 64081

Date: 03/19/2024

Inspector: Marcus Barnes

Temperature (F): 40

Weather: Sunny

OBSERVATIONS

Location: North side of entrance roadway parking area

Equipment Used:

Tandem truck weighing approximately 72000 pounds

Description Of Subgrade: Dark brown clay

Acceptance of Subgrade: Yes

Remarks:

All areas good besides 10 foot radius around extruding pipeline. Rutting exceeding 1 inch but no more than 2 inches.

Reviewed by: Cody Curtis

03/20/2024