



Footing Inspection

Alpha Omega Geotech, Inc
1701 State Avenue
Kansas City, KS 66102
Phone: 913-371-0000

Client:
Tailor Made Exteriors
1610 SE Hamblen Rd
Lee's Summit, MO 64081

Project:
230445
TM Fieldhouse
1600 SE Hamblen Rd
Lees Summit, MO 64081

Date: 05/15/2024

Inspector: Bryce Enzbrenner

OBSERVATIONS

Location of Footings Inspected: Far west side of site by embankment for footings

Plans Used: Structural

Drawing Number: N/A

Type Of Footing Inspected: Strip Footings

Allowable Bearing Capacity (psf): 3000

Footing Excavation per Contract Documents: Yes

Discrepancy: Yes

Remarks:

Footing psf might be incorrect there was no use in getting a sheet number at this point because the footing was so wet/damp



Footing Inspection

Alpha Omega Geotech, Inc
1701 State Avenue
Kansas City, KS 66102
Phone: 913-371-0000

Client:
Tailor Made Exteriors
1610 SE Hamblen Rd
Lee's Summit, MO 64081

Project:
230445
TM Fieldhouse
1600 SE Hamblen Rd
Lees Summit, MO 64081

DISCREPANCIES

Discrepancy Number: 1 **DiscrepancyStatus:** Open

Discrepancy Description:
Almost entire footing had water spots and wet spots up to 5-7 inches deep. We agreed that a top layer needs to come off the entire footing and then it Needs to dry out which they said they're pulling the rebar and going to let it dry.