



Reinforcing Steel Inspection

Alpha Omega Geotech, Inc
1701 State Avenue
Kansas City, KS 66102
Phone: 913-371-0000

Client:
Tailor Made Exteriors
1610 SE Hamblen Rd
Lee's Summit, MO 64081

Project:
230445
TM Fieldhouse
1600 SE Hamblen Rd
Lees Summit, MO 64081

Date: 05/30/2024

Inspector: Apex Engineers

OBSERVATIONS

Location of Inspection: Walls at the loading dock

Plans Used: Structural Plans

Drawing No.: NA

Reinforcing Steel in General Accordance with Contract Documents?: Yes

Discrepancy: No

Remarks:

Wall dimensions, wall reinforcement, anchor bolts, concrete placement observation, and testing of the walls at the loading dock. The wall dimensions, reinforcement, and anchor bolts were found to be acceptable per the plan requirements.