

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Tuesday, June 04, 2024

Informational:

1 Misc

Corrective Action Required:

2 FIRST FLOOR

Building A:

- Decks approved
- Shear wall framing ok for plywood
- Shear wall nailing pattern ok

*UNITS APPROVED EXCEPT AS NOTED BELOW

- Provide 1.5" of bearing for beam outside of unit 289

**Building C:

- Pre rock behind tubs and showers approved

Corrective Action Required:

3 SECOND FLOOR

Building A:

- Decks approved
- Shear walls approved

Building B:

- Shear walls behind tubs ok
- Deck framing ok

		**Building C:
		-Pre rock behind tubs and showers approved
Corrective Action Required:		
4	THIRD FLOOR	*BUILDING A:
		-Approved
		*Building B:
		Approved
		**Building C:
		-2 HOUR WALLS OK FOR ROCK
Corrective Action Required:		
5	FOURTH FLOOR	*BUILDING A:
		-Approved
		*Building B:
		-Approved
		*Building C:
		-OK for pre rock behind tubs and showers
Corrective Action Required:		
6	ELEVATOR 1	**ELEVATOR A:
		-Ok for rock on inside of shaft all floors
Corrective Action Required:		
7	STAIR TOWER 5	Stair tower D:
		-Shear wall nailing pattern complete
Corrective Action Required:		
8	STAIR TOWER 1	*Stair A
		-Approved walls and ceiling all floors
Corrective Action Required:		
9	ELEVATOR 2	Elevator in building C
		-Framing approved
Corrective Action Required:		
10	STAIR TOWER 2	Stair 2 in Building B
		-Approved walls and ceiling all floors
Corrective Action Required:		
11	STAIR TOWER 3	Stair 2B in Building B
		-Approved walls and ceiling all floors

Comments: