

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240645
Address: 904 NW PRYOR RD, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Robb Popp	Failed	Tuesday, June 04, 2024

Corrective Action Required:

1	Misc	-Paint exterior metallic gas lines with corrosion resistant paint **Pressure test ok
---	------	---

Comments: