

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240645  
Address: 904 NW PRYOR RD, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                    | Inspector: | Outcome: | Date:                  |
|------------------------------------------------|------------|----------|------------------------|
| <b>Occupancy Inspection - Codes Commercial</b> | Robb Popp  | Failed   | Tuesday, June 04, 2024 |

Corrective Action Required:

|   |      |                                                                                |
|---|------|--------------------------------------------------------------------------------|
| 1 | Misc | -Provide plumbing protection at restrooms<br>-Paint gas lines<br>-label panels |
|---|------|--------------------------------------------------------------------------------|

**Comments:**