CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241619

Address: 1805 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Kyle Beard Failed Wednesday, June 05,

Residential 2024

Corrective Action Required:

1 Miscellaneous - Exterior sheeting is not nailed to both top plates

Correction - Exterior sheeting is not extended to both top plates

- This inspection was for a garage portal framing only

Comments: