

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20240499  
Address: 2237 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Electrical Inspection - Commercial</b>	Khanh Nguyen	Failed	Wednesday, June 05, 2024

Corrective Action Required:

1	Misc	-Provide #6 copper EGC for 110 amp circuit breaker to transformer -Provide #4 copper or #2 AL GEC for transformer grounding to building steel -Provide #4 copper or #2 AL system bonding jumper -Provide #4 copper or #2 AL supply-side bonding jumper
---	------	---

Comments: