

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20242204  
Address: 202 SE 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Robb Popp	Failed	Thursday, June 06, 2024

Corrective Action Required:

1	Misc	-Provide address at meter can
		-(2) ground rods must be min 6' apart

Informational:

2	Misc	***METER ALREADY INSTALLED BY EVERGY
---	------	--------------------------------------

**Comments:**