

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20114000	Date:	September 13, 2011
Project Title:	SUMMIT FAIR, BLDG C WHITE BOX FINISH	Applicant:	Consolidated Fire Protection
Location:	910 NW BLUE PKWY, Unit:R LEES SUMMIT, MO 64086		14130 Dugan Drive Kansas City, MO 64152 (816) 891-1099
Type of Work:	Sprinkler Alteration		
Occupancy Group:	UC		
Description:	WHITE BOX INCLUDING SINGLE RESTROOM AND SUSPENDED CEILING		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received for 910 NW Blue Parkway, Suite R on Sept. 2, 2011.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

3. For information only- Plan design shall be to the 2002 Edition of NFPA 13 and the 2003 Edition of the IBC.

4. Sprinkler head model to be confirmed at inspection.