

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234291
Address: 2107 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, June 06, 2024

Corrective Action Required:

1 Misc

- provide as graded plot plan
- afci protection for breaker 9 sub panel 17 main
- 1 outlet per vehicle bay as required by code
- address post to beam connections, update to show different beam used for deck
- remove pressure gauge for gas line at furnace
- secondary locking device at rear sliders
- complete generator install

Comments: