

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241323
Address: 1929 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Thursday, June 06, 2024

Informational:

1	Misc	-Garage portal frame okay to cover
---	------	------------------------------------

Corrective Action Required:

3	Miscellaneous Correction	-Have engineer address over bored floor/ceiling joist in living room for 3 inch plumbing waste line -Living room triple window header is not to approved plan -Small garage attic access is not in code compliance of 30 inches of head room space
---	--------------------------	--

Comments: