

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226005
Address: 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Engineering	Patrick Schonfeldt	Temporary C of O	Thursday, June 06, 2024

Informational:

1	Misc	- Provide splash blocks at downspouts, min 36" discharge from foundation - Connect sewer tracer wire to tracer box and set tracer box to grade
---	------	---

Engineering TCO approval, 30 days

Comments: