

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242156  
Address: 2760 SW 11TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:    | Outcome: | Date:                   |
|------------------------|---------------|----------|-------------------------|
| <b>Erosion Control</b> | Shawn Hoffman | Failed   | Thursday, June 06, 2024 |

Corrective Action Required:

|   |   |   |
|---|---|---|
| 1 | DCM1 ESC<br>REQUIRED NO<br>FURTHER INSP | EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE<br>PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.<br><br>- REMOVE ORI TOILET FROM TOP OF STORM INLET<br>- PLACE SILT FENCE OR PROTECT SPOILS PILL NEXT TO FIORD DRIVE FROM<br>ENTERING STREET<br>- POST ADDRESS |
|---|---|---|

**Comments:**