## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20240903

Address: 1924 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Kyle Beard Failed Friday, June 07, 2024

Residential

Corrective Action Required:

Correction

3 Miscellaneous 1924 SW Merryman. All rough

•-Fire block the top of the chases in the garage

•-Renail interior WSP per code or per engineer's letter that needs to be

uploaded

•-Garage anchor bolts need to be in the middle 1/3 of sole plate

•-Two studs are missing in the front entry the the front door south side,

plans call for a 3 stud pack

**Comments:**