CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241323

Address: 1929 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Kyle Beard Failed Friday, June 07, 2024

Residential

Corrective Action Required:

2 Miscellaneous -Have engineer address over bored floor/ceiling joist in living room for 3 inch

Correction plumbing waste line.

-Engineers letter was never uploaded for review before site inspection

Comments: