

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241323
Address: 1929 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Monday, June 03, 2024

Informational:

1 Misc -Garage portal frame okay to cover

Corrective Action Required:

3 Misc -Truss to box wall at ceiling in master north side needs re-nailed or add 2x4 bracing
-J3 truss at northwest corner crooked-needs straightened
-Secure 2x4 in closet of bedroom 2
-Add 2x4 at upstairs guest bathroom
-Address bathroom vent fan in basement bathroom-not mounted
-Address loose fire blocking every ten feet in basement

Comments: