

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20241627
Address: 2861 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Friday, June 07, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Fire approval required-Provide egress pathway from/to kiosk per code (stair, handrail, etc)-Secure MC within 12" of all boxes-Shall secure all wiring above ceiling per code-Plumbing not per plan. Provide 3" waste drain with waste receptor per plan-Flexible cable shall not installed as a substitute for the fixed wiring of a structure. Provide appropriate wiring method to kiosks-Wiring shall be sized per note 6 of electrical plan-Label all breakers of kitchen panel-All receptacles inside kitchen shall be gfci-protected per NEC 210.8(B)(2)
---	------	---

Comments: