

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20215636
Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	Devon Perry	Partial	Monday, June 10, 2024

Informational:
1 Misc 6-7-24 DP. Air pressure testing

Line D
Z3-C1 Passed
Z3-D1 Passed

Line A
A1-16-010 Passed
A1-A2 Passed
A3-A4 Passed
A5-A4 Passed
A5-B1 Passed
A5-A6 Passed

Line E
A6-E1 Passed

Line B
B2-B1 Passed
B2-B3 Passed

****STILL NEEDING TO BE TESTED****

Line A from MH A6 to MH A8

Comments: