

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20215636
Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Devon Perry	Partial	Monday, June 10, 2024

Informational:

1	Misc	6-6-24 DP. Mandrel testing- B3-B2 Passed B2-B1 Passed B1-A5 Passed A5-A4 Passed A4-A3 Passed A3-A2 Passed A2-A1 Passed A1- MH 16-010 Passed Z3-D1 (Ductile pipe) C1-Z3 Passed A5-A6 Passed E1-A6 Passed
---	------	---

STILL NEEDING TO TEST onces 30 days is up, A6 to A7 and A7 to A8

Comments: