

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20215636  
Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Devon Perry	Partial	Monday, June 10, 2024

Informational:  
1 Misc 6-7-24 DP. Vacuum testing

MH 16-006 Passed  
MH Z1 Passed  
MH Z2 Passed  
MH D1 Passed  
MH Z3 Passed  
MH C1 Passed  
MH 16-010 Passed  
MH A1 Passed  
MH A2 Passed  
MH A3 Passed  
MH A5 Passed  
MH A6 Passed  
MH E1 Passed  
MH B1 Passed  
MH B2 Passed  
MH B3 Passed

**\*\*STILL NEED TO TEST\*\***  
MH A-7  
MH A-8

Corrective Action Required:

2	Miscellaneous Correction	6-7-24 DP. MH 16-008 failed MH 16-009 needs backfilled MH A-4 failed
---	-----------------------------	-------------------------------------------------------------------------------

**Comments:**