

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240903
Address: 1924 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Partial	Monday, June 10, 2024

Corrective Action Required:

1	Miscellaneous Correction	Repair or replace silt fence at the street where it is damaged.
---	-----------------------------	---

Full erosion control must be maintained until CofO

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	6-10-24 Dustin A, EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. Street needs to be cleaned
---	----------------------------	---

Comments: