

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240229
Address: 2116 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Monday, June 10, 2024

Corrective Action Required:

1	Misc	-Protect NM cable in hallway near single car garage south side -Move 2x4 brace to opposite side of joist just below each rafter -Protect NM cable left of front door -Missing fire blocking behind basement shower -Provide access to inspect gas line at deck fireplace -Provide more bracing at ceiling of #5 bedroom bathroom -Provide more bracing at ceiling of #4 bedroom
---	------	---

Comments: