

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20235554

Address: 816 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
818 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
64064814 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, June 11, 2024

Corrective Action Required:

1	Misc	Unit 814 and 818 only-OK to rock
---	------	----------------------------------

Unit 816:

-Cannot have roof ventilation opening located within 4 ft of firewall. Provide FlameBlock roof deck sheathing within 4 ft of firewall. Check all other units

**\*\*Cut out bigger pieces of FlameBlock sheathing or Sheetrock and cover the over-exposed edges**

Comments: