

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234022
Address: 2302 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Tuesday, June 11, 2024

Corrective Action Required:

2	Misc	-Missing GFCI at washing machine -Missing Security Screws at front and back doors -Remove dust covers on Smokes -Missing switch in master bedroom -Cut Ufer ground to safe height -Missing tamper proof caps at AC compressor -Seal wall penetrations at line sets
---	------	--

Comments: